

Source Protection Rules
309-600-13(3)

(3) Sewers Within DWSP Zones and Management Areas - Sewer lines may not be located within zones one and two or a management area unless the criteria identified below are met. If sewer lines are located or planned to be located within zones one and two or a management area, the PER must demonstrate that they comply with these criteria. Sewer lines that comply with these criteria may be assessed as adequately controlled potential contamination sources.

(a) Unprotected Aquifers -

(i) Zone one - sewer lines and laterals shall be at least 50 feet from the wellhead or margin of the collection area, and be constructed in accordance to R309-515-6.

(ii) Zone two - all sewer lines and laterals within zone two or a management area shall be constructed in accordance with R309-515-6.

(b) Protected Aquifers – in zone one all sewer lines and laterals shall be constructed in accordance to R309-515-6, and shall be at least 10 feet from the wellhead or margin of the collection area.